

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY
(WATER ANALYSIS REPORT)

REF. NO: -1139

REF. DATE: 05 /05/26

Sample provided by :-Guru Amar Dass Public School, G.T.B Nagar, Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 - 8.5	7.4
5	DISSOLVED SOLIDS (TDS)	500 ppm	157
6	TOTAL HARDNESS (as CaCO ₃)	300 mg/l	106
7	ALKALINITY	200 mg/l	92
8	CALCIUM (as Ca ⁺⁺)	75 mg/l	14.2
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	48
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per applied tests



DATE:-07 /05/26

Ajeet Kumar
Analyst
ANALYST
MUNICIPAL CORPORATION JALANDHAR

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)

REF. NO: -1138


REF. DATE: 05 /05/26

Sample provided by :-Guru Amar Dass Public School, Model Town, Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 – 8.5	7.4
5	DISSOLVED SOLIDS (TDS)	500 ppm	145
6	TOTAL HARDNESS (as CaCO ₃)	300 mg/l	98
7	ALKALINITY	200 mg/l	90
8	CALCIUM (as Ca ⁺⁺)	75 mg/l	14.0
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	46
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per applied tests



DATE:-07 /05/26

Neelesh Kumar
Analyst
ANALYST
MUNICIPAL CORPORATION JALANDHAR